

Approval Number: 1909513  
Test Report: J-00335646



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

16<sup>th</sup> September 2019

Gulf Pipe Industries L.L.C.  
#113, Al Ahbabi Buildings,  
Al Qusais,  
P. O. Box 66575,  
Dubai,  
U.A.E.

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**GLASS REINFORCED PLASTICS (GRP) - COMPONENTS.**

**5120**

'Fibre Gulf GRP Pipe'. Light green/off-white coloured GRP pipe manufactured by filament winding. For use with water up to 50°C.

**APPROVAL NUMBER: 1909513**  
**APPROVAL HOLDER: GULF PIPE INDUSTRIES L.L.C.**

The Scheme reserves the right to review approval.  
Approval 1909513 is valid between September 2019 and September 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme