

Approval Number 2310552  
Test Report: J-00459979



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

24<sup>th</sup> November 2023

Gulf Pipe Industries L.L.C.  
P. O. Box 66575  
403, Red Crescent building,  
AL Garhoud,  
Dubai,  
United Arab Emirates

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**GLASS REINFORCED PLASTICS (GRP)- COMPONENTS.**

**5120**

'Fibre Gulf'. GRP pipe which is has a brown/yellow coloured water contact layer and a beige coloured outer layer, manufactured by filament winding and contact moulding. For use with water up to 60°C.

**APPROVAL NUMBER: 2310552**  
**APPROVAL HOLDER: GULF PIPE INDUSTRIES L.L.C.**

The Scheme reserves the right to review approval.  
Approval 2310552 is valid between October 2023 and October 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

**Ian Hughes**  
**WRAS Approvals Manager**